

Month	Total LADWP Generation resources	All-time Peak load	Forecasted 1 in 2 Peak load	Contractual Imports	N-1 Required Reserves	N-1-1 Reserves (Not required)	VER Reserves (Not required)	All-time Peak Surplus Capacity	1 in 2 Surplus Capacity
June	7164	6056	4867	35	575	553	400	-385	804
July	7699	6502	5154	177	575	562	400	-163	1185
August	7911	6502	5604	177	575	562	400	49	947
September	7668	6502	5550	177	575	562	400	-194	758

Month	Total LADWP Generation resources	External Generation (Apex, IPP, PV)	Hydro generation	Renewables	In-basin Thermal
June	7164	1431	1700	1214	2819
July	7699	1431	1682	1443	3143
August	7911	1667	1683	1418	3143
September	7668	1350	1607	1346	3365

Average Resource Mix available at Peak Load

